



# Hunt County Health Department

2701 Johnson Street

Greenville, TX 75401

Telephone: 903-408-4140 Fax: 903-454-3913 [www.huntcounty.net](http://www.huntcounty.net)

## SWIMMING POOL/SPA ELECTRICAL REQUIREMENT CERTIFICATION

Property Name: \_\_\_\_\_ Pool/Spa Name: \_\_\_\_\_

Please **initial** each of the following items to certify that all criteria are in proper working condition at all pool or spas as required by Hunt County. If an item is not applicable to the pool/spa, please enter "N/A".

**It is the responsibility of the electrical contractor to ensure the GFCI inspection meets all federal, state, and local electrical codes. This inspection must include the checklist but is not limited to those items.**

- \_\_\_\_\_ Each electrical outlet within the enclosure and in a dressing or toilet facility is GFCI protected.
- \_\_\_\_\_ Each electrical line to an underwater light is GFCI protected (must be located in the circuit breaker at the breaker box for the light or in an outlet through which the power for the light passes)
- \_\_\_\_\_ If the switch that serves lights or equipment (other than pumps and underwater lights) is between 5 and 10 feet from the pool/spa wall, each electrical line to the switch must be grounded and have a GFCI located either: 1) in the circuit breaker for the light; or 2) in the equipment circuit that powers the switch at the breaker box; or 3) in an outlet through which the power for the switch passes.
- \_\_\_\_\_ All GFCIs and circuit breakers comply with 2020 NEC requirement.
- \_\_\_\_\_ Electrical equipment is grounded according to the 2020 NEC
- \_\_\_\_\_ Pumps are both internally and externally grounded.
- \_\_\_\_\_ Electrical disconnecting means is accessible for service personnel, located within sight of the pool/spa equipment, and located farther than 5 feet from the inside pool/spa wall as required by the 2014 NEC. Each disconnecting means must disconnect all ungrounded conductors to the equipment it serves. Any metal within 5 feet of water's edge shall be bonded per 2020 NEC.
- \_\_\_\_\_ Electrical equipment (including switches, outlets, deck lights, pumps, and other electrical equipment) are located farther than 10 feet from the inside pool/spa wall unless:
  - a) the electrical equipment is at least 5 feet from the pool/spa wall and is separated by a fence, wall, or other permanent barrier at least 4 feet high;
  - b) the electrical equipment is at least 5 feet from the wall of the pool/spa and:
    - a. consists of only one outlet for an electrical line that is grounded, has a GFCI, and has a locking mechanism covering the outlet;
    - b. consists of one or more switches serving electrical lines that are grounded and that have GFCI protection that is in the circuit breaker for the equipment at the breaker box or in an outlet through which the power for the equipment passes; or
    - c. consists of an electrical device other than the outlet or switch and complies with applicable NEC requirements at the time of installation.

**I attest that I am a certified electrician and I am qualified to perform the above inspection**

Signature: \_\_\_\_\_

Printed Name: \_\_\_\_\_

License Number: \_\_\_\_\_

Date: \_\_\_\_\_

Email: \_\_\_\_\_

Phone: \_\_\_\_\_